

2020 ACCESSIBILITY ANNUAL REPORT - IDENTIFIED BARRIERS

ALMONTE DAYCARE CENTRE – 208 STATE STREET						
TYPE OF BARRIER	LOCATION	DESCRIPTION	REMEDY	PRIORITY	ESTIMATED COMPLETION DATE	COMMENTS
P	Almonte Daycare	No elevator to second floor	Install elevator	Low	Major renovation	If a child with disabilities attends the daycare their programming takes place on first floor
P	Almonte Daycare	Accessible Parking	Install more spaces	Medium	2025	No place to drop off persons with disabilities and parking is limited
P	Almonte Daycare - Washrooms	Doorways, sinks taps, counters, toilets	Lower counters upgrade fixtures, install accessible doors with push buttons and alarms	Medium	2025	If a child with disabilities attends they cannot reach the taps, or use facilities at ease, and no privacy.
A new daycare location at Holy Name of Mary opened in 2019 and is fully accessible. Any child requiring greater accessibility would be provided a spot at that location.						

ROADS & PUBLIC WORKS – 3131 OLD PERTH RD						
TYPE OF BARRIER	LOCATION	DESCRIPTION	REMEDY	PRIORITY	ESTIMATED COMPLETION DATE	COMMENTS
P	Municipal Garage - Washrooms	Not accessible	Renovation	Low	2022+	Pending Facility Needs Assessment
P	Municipal Garage - Entrance	Not accessible	Renovation	Low	2022+	Pending Facility Needs Assessment

2020 ACCESSIBILITY ANNUAL REPORT - IDENTIFIED BARRIERS

A	Sidewalks in Almonte and Pakenham	Sidewalks are uneven and not all sloped to accommodate passage by wheelchairs and strollers	Reconstruct sidewalks	High	Incorporated yearly	Each year there is a budget allocated to sidewalk repairs. The list of repairs is prioritized by Public Works Department.
P	Sidewalk on Little Bridge Street	Sidewalk too high off the road	Extend railing	Medium	2021-2022	Little Bridge Street sidewalk will likely be addressed when the downtown revitalization project is realized likely in 2021-2022

PUBLIC LIBRARY – ALMONTE BRANCH – 155 HIGH ST

TYPE OF BARRIER	LOCATION	DESCRIPTION	REMEDY	PRIORITY	ESTIMATED COMPLETION DATE	COMMENTS
P	Reception counter	Counter requires an overhang to accommodate a wheelchair	Move the counter wall	Low	2020-22	A new strategic plan for 2017-27 identifies a space needs assessment for the Almonte branch renovation including accessibility which will include a redesign of the service counter. Patrons using wheelchairs can approach the accessible low counter for exchange of materials. Desk will be reconfigured in 2020 to accommodate until renovation. Estimated cost-\$500.
P	Door leading into meeting area	Door is too narrow to accommodate wheelchair	Enlarge doorway	Low	2020-22	The door from the quiet room meets accessibility standards (greater than 32 inches). The other door will be widened when the Almonte Branch is

2020 ACCESSIBILITY ANNUAL REPORT - IDENTIFIED BARRIERS

						renovated in 2022. Estimated cost (if done outside of renovation) - \$3000.
--	--	--	--	--	--	--------------------------------------------------------------------------------

ALMONTE OLD TOWN HALL – 14 BRIDGE STREET

TYPE OF BARRIER	LOCATION	DESCRIPTION	REMEDY	PRIORITY	ESTIMATED COMPLETION DATE	COMMENTS
P	Sidewalks	Uneven, cracked	Need repair	Low	2025	Hard for someone in a wheel chair to maneuver. This will be addressed by Public Works during their annual budget for sidewalk repair.
P	Washrooms on first floor	Doors are not automated	Install power assist doors	Low	2020-2022	

ALMONTE & DISTRICT COMMUNITY CENTRE – 182 BRIDGE STREET

TYPE OF BARRIER	LOCATION	DESCRIPTION	REMEDY	PRIORITY	ESTIMATED COMPLETION DATE	COMMENTS
P	Access onto the Curling Rink Surface	No accessible access onto curling slab, 2 sets of steep stairs	Review options	Low	2022+	Complete a detailed review of accessible options (eg. stairlift, ramp, renovation) for access to curling rink. Options were presented to AAC for consideration. Will require approx. \$50,000 to complete

2020 ACCESSIBILITY ANNUAL REPORT - IDENTIFIED BARRIERS

GEMMILL PARK – 182 BRIDGE STREET						
TYPE OF BARRIER	LOCATION	DESCRIPTION	REMEDY	PRIORITY	ESTIMATED COMPLETION DATE	COMMENTS
P	Gemmill Park parking lot	Access from parking lot to park has large gravel and is hard for wheelchairs and walkers	Pave a path or sidewalk to park entrance	Low	2022	

MUNICIPAL BUILDING – 3131 OLD PERTH RD						
TYPE OF BARRIER	LOCATION	DESCRIPTION	REMEDY	PRIORITY	ESTIMATED COMPLETION DATE	COMMENTS
P	Public washrooms	Accessible washroom doors are not automated	Install automated doors	Low	2022	